

Liberty 933 Eloise Avenue South Lake Tahoe, CA 96150 Tel: 800-782-2506 Fax: 530-544-4811

October 30, 2024

## DATA REQUEST RESPONSE

### LIBERTY UTILITIES (CALPECO ELECTRIC) LLC

Data Request No.:	OEIS-P-WMP_2024-LU-006
Requesting Party:	Energy Infrastructure Safety
Originator:	Jessica McHale, Wildfire Safety Analyst Jessica.McHale@energysafety.ca.gov
Cc:	Nicole Dunlap <u>Nicole.Dunlap@energysafety.ca.gov</u> Johan Im <u>Johan.Im@energysafety.ca.gov</u> Ethan Campos <u>Ethan.Campos@energysafety.ca.gov</u>
Subject:	<ul> <li>Q01. Regarding the Stateline Resiliency Project completion date</li> <li>Q02. Regarding interim risk mitigations on circuits impacted by the Stateline Resiliency Project completion date</li> </ul>
Date Received:	October 25, 2024
Due Date:	October 30, 2024

#### <u>Question 1</u>: Regarding the Stateline Resiliency Project completion date:

a. What is Liberty's estimated completion date for the Stateline Resiliency Project?

#### **Response to Question 1:**

a. The estimated completion date for the Stateline Resiliency Project is November 1, 2026.

# <u>Question 2</u>: Regarding interim risk mitigations on circuits impacted by the Stateline Resiliency Project completion date:

- a. Does Liberty plan to mitigate risk on circuits STL2200 and STL2300 in 2025 via interim mitigations such as SRP, additional asset or vegetation management inspections, or traditional hardening?
  - i. If so, please provide details on interim mitigation plans for these circuits.

#### **Response to Question 2:**

- a. Yes.
  - In 2025, Liberty will include both circuits STL2200 and STL2300 in its Vegetation Management Patrol Inspections (WMP-VM-INSP-02). Additionally, circuit STL2200 is included in Liberty's Detailed Asset Inspection (WMP-GDOM-AI-01) schedule for 2025 and circuit STL2300 will be included in Liberty's Patrol Asset Inspections (WMP-GDOM-AI-03) in 2025.