



Liberty
933 Eloise Avenue
South Lake Tahoe, CA 96150
Tel: 800-782-2506
Fax: 530-544-4811

October 20, 2026

DATA REQUEST RESPONSE
LIBERTY UTILITIES (LIBERTY)

Data Request No.: OEIS-P-WMP_2026-Liberty-009

Requesting Party: Office of Energy Infrastructure Safety

Originator: Jessica McHale, Wildfire Safety Analyst
Jessica.McHale@energysafety.ca.gov

cc: Dakota Smith
Dakota.Smith@energysafety.ca.gov
Jolynne Flores
Jolynne.Flores@energysafety.ca.gov
Francis Solis
Francis.Solis@energysafety.ca.gov
Will Dundon
Will.Dundon@energysafety.ca.gov

Date Received: October 16, 2026

Due Date: October 21, 2026

Subject: Q01. Regarding SRP setting review

Q01. Regarding SRP setting review:

On page 165 of its 2027 Base WMP,¹ Liberty states that it “will continue to perform its review of one-third of its circuits annually and look for opportunities to improve and expand the [SRP] program.” In contrast, on page 204, Liberty states that it “will start reviewing a third of the circuits every three years to check that the settings remain optimized to reduce wildfire risk.”

- a. Please confirm whether the intent is to review one-third of its circuits annually or explain otherwise.

Response:

- a. Liberty confirms that it plans to review its SRP settings on one-third of its circuits annually.