Welcome

Liberty Utilities Reliability Reporting Workshop for 2019 Calendar Year

December 2, 2020



Virtual Meeting Info for You

- The audience will be on mute. You will be able to hear and see the presenters.
- If you have questions, please type them in the chat/question box area which should be to the right of your screen.
- Questions will be answered at the end of the presentation.
- Sometimes there can be technical difficulties. Please bear with us in case we need to work through them.





Agenda

- Purpose of Workshops
- System Overview
- Key Utility Initiatives
- Reliability Performance
- Questions








Service Territory Overview

- Purchased NV Energy's (SPPCo)
 California service territory in 2011
- 1,476 square miles; 49,000 customers
- Two office locations: South Lake Tahoe and Tahoe Vista
- Pay \$2.8 million in annual property taxes and franchise fees in 7 counties
- Approximately 100 employees currently
- Regulated by the California Public Utilities Commission (CPUC)
- Winter Peaking Utility





Service Territory Overview


- 1,880 miles Distribution lines
 - 1,400 Overhead (O/H)
 - 480 Underground (U/G)
- I3 Substations
- 12MW of Emergency Diesel Generation



- Max System Load: 144.5 MW (Dec 2012)
- 88% Residential, 12% Commercial



Where Does The Power Come From



Factors for Customer Satisfaction


- ➤ Reliability
- Safe Service
- > Outage Notification

Region	Incidents	Aff	Served	%	Estimated Restoration Times
Alpine	0	0	477	0%	
El Dorado	0	0	23721	0%	
Mono	0	0	661	0%	
Nevada	0	0	1310	0%	
Placer	0	65	16614	0.4%	
Plumas	0	0	1774	0%	
Sierra	0	0	791	0%	
Total	0	65	45348	0.1%	



Outage Reporting and Tracking

Please Call 1-844-245-6868






Customer Notifications



Power System Overview





- Weather (wind, snow, ice build up, lightening)
- Animals (birds, squirrels, snakes)
- Third Party Damage (motor vehicle accident)
- Equipment Failure (cable faults, transformer)
- Vegetation (trees, wild fire)
- Loss of Source Power from NV Energy









Momentary vs. Sustained



Momentary

Outages that are less than or equal to 5 minutes in duration **Ex:** Tree branches contact a power line, burns the branch clear, and the circuit recloses automatically

<u>Sustained</u>

Outages that are greater than 5 minutes in duration

EX: Tree falls through the power line and must be removed before re-energizing the line



Planned vs Major Outages

Planned Outage

- Outages where a customer or public official has made a request, or Liberty has provided notification
- These are excluded from reliability metrics

<u>Major Event</u>

 Institute of Electrical and Electronic Engineers (IEEE) standard 1366– 2012, a set of outages that exceed the historically expected outage duration (SAIDI) for at least one day





Every outage is analyzed to determine the following metrics:


SAIDI = $\frac{Total \ of \ Customer \ Interruption \ Durations}{Total \ number \ of \ customers \ served}$

 $SAIFI = \frac{Total Number of Customers Interrupted}{Total number of customers served}$

 $CAIDI = \frac{Total \ Customer \ Interruption \ Durations}{Total \ Number \ of \ Customer \ Interruptions}$

 $\mathbf{MAIFI} = \frac{Tot.No.of\ Customer\ Momentary\ Interruptions}{Total\ number\ of\ customers\ served}$


SAIDI System Performance





SAIFI System Performance


Distribution System Indices MED Excluded (SAIFI)






CAIDI System Performance

Distribution System Indices MED Excluded (CAIDI)





MAIFI System Performance





Worst Performing Circuits


Circuit	Customers	Substation	Circuit Miles	ОН	UG	Circuit Outages	Circuit SAIDI	Circuit SAIFI
201	64	Washoe	8.7	99.8%	0.2%	4	2931	7.83
1261	749	Topaz	70.9	76.2%	23.8%	7	3040	7.12

Analysis of worst performing circuits excludes planned and Major Event outages.

The preferred metric for this analysis is the 3 year average circuit level SAIDI in order to account for population discrepancies between urban and rural circuits.



Washoe 201 Circuit




- Services Floriston
- Approximately 70 customers
- 247 poles
- 8.7 miles O/H
- Radial source from NV Energy's substation located near Mogul (additional 5 miles)



Reliability Trend

Washoe 201 Reliability Metrics





Significant Outages

March 25th 2019


- □ Loss of source from NV Energy.
- Downed wire found across Hwy.
- Outage Time 9 hours and 17 minutes

July 10, 2017

- □ Wildfire in the area burned several poles
- After the fire was contained and Liberty was granted access, generators were brought in to restore service to Floriston while the line was rebuilt.
- Outage Time 38 hours




Topaz 1261 Circuit



- Services Coleville, Walker
- Approximately 750 customers
- 1,281 poles
- 69.1 miles O/H
- 7.7 miles U/G
- Radial source from Smith Valley, NV

Reliability Trend







Significant Outages

March 15[,] 2019


- Outage for all customers on Topaz 1261
- Downed wire
- Outage Time Partially Restored 2 hours and 24 minutes; Fully Restored 4 hours 36 minutes

March 22, 2019

- Incorrect connections on generator to transformer
- □ Left entire feeder out of power
- Outage Time –32 hours 50% Restored; 48 hours 66% Restored; 56 hours 90% Restored; 58 hours Fully Restored



Reliability Improvements






An aggressive Vegetation Management program – about \$4 million per year



Improved Animal Protection



Precision fit animal guards are being implemented into our substations to prevent wildlife outages.



Wildfire Mitigation Plans

Several projects are underway to reduce fire risk



Some Projects include:

- Advanced weather monitoring
- Covered Conductor
- Expulsion fuse replacement
- Additional recloser installations

Thank you

Email: PowerQuality@libertyutilities.com

Or call Customer Service at 1-800-782-2506

