

Rule No. 17

MEASUREMENT OF SERVICE

A. Measurement of Electric Energy

1. All electric energy as supplied by the Liberty Utilities (CalPeco Electric) LLC its Customers shall be measured by means of suitable standard electric meters, except energy delivered under street lighting tariffs on a rate-per-lamp basis, and energy, estimated from load and operating time data, for highway sign lighting, traffic control and other installations where metering is impractical.
2. For billing purposes, all meters upon the Customer's premises will be considered separately, and the readings thereof will not be combined, except that where the Utility shall, for operating convenience, install upon the Customer's premises, in place of one meter, two or more meters, then the readings of such two or more meters may be combined for billing purposes.

B. Standard of Accuracy.

The average error of a meter is one-half the algebraic sum of the error at light load (1% to 10% of rated capacity) and the error at heavy load (60% to 100% of rated capacity). No meter will be installed which has an error of more than 2% fast or slow at light or at heavy load. Whenever on any test, a meter is found to exceed these limits it will be adjusted or replaced.

(T)

Advice Letter No. 28-E

Issued by

Michael R. Smart

Date Filed July 15, 2013

Name

Decision No. _____

President

Effective July 15, 2013

Title

Resolution No. _____

(T)